

**A.F. COLAFELLA & ASSOCIATES Ply. Ltd.**  
**A.C.N 006 298 399**  
**Consulting Structural & Civil Engineers**

**178 Boronia Road**  
**Boronia, Vie. 3155**  
**Tel: (03) 9762 6466**  
**Fax: (03) 9761 1766**

Friday 1st June, 2001.

Deck Guardrail  
 Unit 4 I 37 Gatwick Rd  
 Bayswater, 3153.

Dear Sir,

RECEIVED  
 - 4 JUN 2001  
 RECEIVED

RE: LIGHT DUTY WORKING PLATFORMS - series 100, 200, 300, 400   
 (INCORPORATING TIE BACK SYSTEM FOR ROOF TRUSS   
 INSTALLATION)

I hereby certify that I have undertaken a structural analysis of the light duty working platform support frames, incorporating the tie back system for bracing of stud walls where used for installation of roof trusses.

The design has been undertaken in accordance with the requirements of the following Australian Standards:

AS/NZS 4576 <input type="checkbox"/> - 1995 <input type="checkbox"/>	GUIDE LINES FOR SCAFFOLDING.
AS/NZ 1576.1 <input type="checkbox"/>	SCAFFOLDING GENERAL REQUIREMENTS.
AS 1664 <input type="checkbox"/> - 1979 <input type="checkbox"/>	ALUMINIUM STRUCTURES CODE. <input type="checkbox"/>
AS 6001 <input type="checkbox"/> - 1999 <input type="checkbox"/>	WORKING PLATFORMS FOR HOUSING <input type="checkbox"/>
	CONSTRUCTION,
AS 1684 <input type="checkbox"/> - 1992 <input type="checkbox"/>	NATIONAL TIMBER FRAMING CODE. <input type="checkbox"/>
AS 2870.1 <input type="checkbox"/> - 1996 <input type="checkbox"/>	TIMBER STRUCTURES CODE (PART 1). <input type="checkbox"/>

I further advise that impact testing of the working platform and guardrail system assembly has been undertaken in accordance with the publication:  
*"The Roof Guard railing Standard 1998"*

Published by Construction Safety Managers and Officers Association Qld Inc. 1998.