

## TEST CERTIFICATE

FOR REPORT MT-07/353-A

**CLIENT:** ATF HIRE GROUP PTY LTD  
LEVEL 2, QUAD 3, 102 BENNELONG ROAD  
HOMEBUSH BAY NSW 2127

**EQUIPMENT DESIGNATION:** *Extended Concrete Bolt-on Guardrail Post*

**MANUFACTURER:** *ATF Hire Group Pty Ltd*

**APPLICABLE STANDARD:** *AS/NZS 4994.1(Int):2004  
Temporary Roof Edge Protection for Housing and Residential  
Buildings, Part 1 General Requirements*

**APPLICABLE CLAUSES:** *AS/NZS 4994.1(Int):2004  
Section 4, Appendix A.*

### COMMENTS:

The ATF Extended Concrete Bolt-on Guardrail post, as described in test report MT-07/353-A has been tested in accordance with AS/NZS 4994.1(Int):2004 Section 4, Appendix A. and has passed the specified requirements for this test.

### CONDITIONS:

- 1) This certificate is specific to the tested unit, tested on the 27/09/2007.
- 2) It remains the responsibility of the client to ensure that the Extended Concrete Bolt-on guardrail post and associated components, as reported in MT-07/353-A are representative of the entire production batch.
- 3) This certificate only covers the structural integrity of the Extended Concrete Bolt-on guardrail post specific to the test procedures outlined in MT-07/353-A.
- 4) Melbourne Testing Services shall take no responsibility for the procurement and authenticity of the Extended Concrete Bolt-on guardrail post as described in MT-07/353-A.
- 5) Melbourne Testing Services shall take no responsibility for the workmanship, safety and performance of Extended Concrete Bolt-on guardrail post other than the assembly described in MT-07/353-A.
- 6) Melbourne Testing Services shall take no responsibility for any subsequent alterations or design changes that may affect the safety and performance of Extended Concrete Bolt-on guardrail post as described in MT-07/353-A.
- 7) Melbourne Testing Services shall take no responsibility for the installation procedures and use of Extended Concrete Bolt-on guardrail post as described in MT-07/353-A.



RODNEY WILKIE  
TEST ENGINEER  
LABORATORY MANAGER

DATE: 08/11/2007