

LEROY PALMER & ASSOCIATES PTY LTD**CONSULTING ENGINEERS**

ACN 078 229 526 ABN 28 141 341 900

Structural Engineering
Civil Engineering
Building Consultants
Project Management
Geotechnical Engineering
Subdivision Consultants

138 Margaret Street
PO Box 1413
Toowoomba 4350
Phone: (07) 4638 7655
Fax: (07) 4638 7633
Mobile: 0417 768 333

7th January 2004

REF: 30001.06

Alquip Pty Ltd
720 Greenwattle Street
Toowoomba 4350

ATTENTION: Mr. Mark Evenden

Dear Mark

ALQUIP PLATFORMS**1.3m, 2.0m, 2.5m AND 3.0m**

We are pleased to provide the following information on the 1.3m, 2.0m, 2.5m and 3.0m Alquip Platforms. The above mentioned Platforms are detailed on Alquip Pty Ltd drawing numbers 6121020, 6122020, 6123020 and 6124020 respectively.

The Alquip 1.3m, 2.0m, 2.5m and 3.0m Platforms have a Working Load Limit of 225Kg. The Platforms have been tested for Strength and Stiffness in accordance with AS/NZS 1576.3:1995. The Alquip Platform complies with the requirements of the above mentioned test procedure.

The Alquip 1.3m, 2.0m, 2.5m and 3.0m Platforms are therefore certified for a Working Load limit of 225 Kilograms. It may be pertinent to note that the Platforms must be located on the supporting Transoms via the Hook assembly incorporated in the platform.

Should you have any queries or require further information, please do not hesitate to contact me.

Yours sincerely



Leroy Palmer
B.Eng Civil, GradIEAust, RPEQ 5208